

## Attestation

### LEED Product Information

#### Product

**Sikaflex PRO-3**

#### Product Type / Application

Sealant - Other

#### Test Method

Sikaflex PRO-3 has been tested as per US EPA Method 24

Result: VOC Content < 420 g/L

#### Summary

Sika certifies that the VOC of Sikaflex PRO-3 conforms on the LEED v3 IEQ credit 4.1 Low Emitting Materials - Adhesives and Sealants

#### Sika Technology AG



Gerhard Leu  
Corporate Analytic Services  
VOC Analytics



Dr. Horst Schneider  
Sika Deutschland GmbH  
E - Technical Services

