

# LEED Attestation

Date 1/8/2010

---

## Attestation

### LEED Product Information

#### Product

**Sikafloor-169**

#### Test Method

Sikafloor-169 has been tested as per EPA Method 24

Result: VOC Content < 100 g/L

#### Summary

Sika certifies that the VOC of Sikafloor-169 conforms on the LEED v3 IEQ credit 4.2 Low Emitting Materials - Paint and Coatings

#### Sika Technology AG



Gerhard Leu  
Corporate Analytic Services  
VOC Analytics



Dr. Horst Schneider  
Sika Deutschland GmbH  
E - Technical Services



Sika Technology AG, Corporate Analytics, Tüffenwies 16, 8048 Zürich, Switzerland  
Tel. +41 58 436 43 52, Fax +41 58 436 46 60, [www.sika.com](http://www.sika.com)  
e-mail: [leu.gerhard@ch.sika.com](mailto:leu.gerhard@ch.sika.com)