



88 Empire Drive • St. Paul, Minnesota • 55103
 (651) 642-1150 • fax (651) 642-1239

VOC Content Test Certificate

October 25, 2011

Supplier: Hilti Entwicklungsgesellschaft mbH
 BU Anchors
 Hiltistrasse 6
 86916 Kaufering
 GERMANY

Sample Description: Hilti HIT-HY 200-R

Date Tested: October 4, 2011

Test Method: SCAQMD method 304-91 "Determination of Volatile Organic Compounds (VOC) in Various Materials" as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168. The values also comply with the requirements of EPA test method #24.

Test Data:

Specification	Product
LEED 2009 (LEED 3.0) LEED 2.2 IEQ-4.1: Low-Emitting Materials – Adhesives and Sealants	Hilti HIT-HY 200-R
Green Building Council of Australia Green Star Office Design 3.0, IEQ-13 Green Star Office Design 2.0, IEQ-13 Green Star Office Interiors 1.1, IEQ-11	
Multipurpose Construction Adhesive; VOC Limit: 70 g/L	Product contains: 13 g/L of VOC

Tom Barrett
 Vice President/Strategic Analytical Services

Kelly French
 Chemist III/Lab Supervisor